



**BUREAU  
VERITAS**

**Bureau Veritas  
Consumer Products Services  
Germany GmbH**

Businesspark A96  
86842 Türkheim  
Germany  
+ 49 (0) 40 740 41 – 0  
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH  
Accredited according to EN 45011 -  
ISO / IEC Guide 65

## Certificate of compliance

**Applicant:** **JIANGSU GOODWE  
POWER SUPPLY TECHNOLOGY CO.,LTD**  
NO.189 Kun Lun Shan Road  
Suzhou New District.jiangsu  
China

**Product:** **Photovoltaic (PV) inverter**

**Model:** **GW10K-DT, GW12K-DT, GW15K-DT,  
GW17K-DT, GW20K-DT**

**Use in accordance with regulations:**

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

**Applied rules and standards:**

**NRS 097-2-1:2010 ed1.0**

Grid interconnection of embedded generation  
Part 2: Small-scale embedded generation  
Section 1: Utility interface

**IEC 61727:2004 ed2.0**

Photovoltaic (PV) systems – Characteristics of the utility interface

**IEC 62116:2008 ed1.0**

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

**DIN V VDE V 0126-1-1:2006-02 (Functional safety)**

Automatic disconnection device between a generator and parallel to the public low voltage network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** **13TH0422-NRS 097-2-1**

**Certificate number:** **U13-0723**

**Date of issue:** **2013-10-09**      **Valid until:** **2016-10-08**

**Certification body**

Dieter Zitzmann



QUALITY



HEALTH



SAFETY



ENVIRONMENT



SOCIAL  
ACCOUNTABILITY